

#### POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

#### STANDARD USAGE CONDITIONS:

1. Altitude: below 1000 meters;

2. Environmental temperature: 25 °C

3. Relative humidity: 30%

#### ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual. The noise value we provide is based on laboratory testing and is for reference.

#### QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:

ISO 1400:2015 Environmental System;

ISO 45001:2018 Safty System;

ISO 9001:2015 Quality System

SERVICE		PRP	ESP
Power	KVA	250	275
Power	KW	200	220
Standard Voltage	V	400/230	
Available Voltage	V	380/220	415/240
Rated Current	A	361	
Frequency/Speed	HZ/RPM	50/	1500

### Weight and Dimension

	Dimension	ı	0pen	Silent
Length	(L)	mm	3150	3960
Width	( W)	mm	1100	1280
Height	(H)	mm	1950	2150
Net Weigh	t	KG		
Fuel Tank		L		648

# IG275C

# INDUSTRIAL RANGE POWER BY CUMMINS



## Engine Specifications

General Engine Date -	- CUMMINS CCEC
Engine Model	NTA855-G1
Governer	E
Cycle	4 stroke
No. of Cylinders	6
Displacement (L)	14
Bore* Stroke (mm)	140*152
Compression Ratio	14. 5
Rated Net Power (KW)	200
Aspiration	Turbocharged, Aftercooled

Fuel System		
Clean Fuel Filter	kPa	13.5
Dirty Fuel Filter	kPa	27. 1
Minimum Fuel Supply Line Size	mm	16
Minimum Fuel Return Line Size	mm	13
Maximum Fuel Pump Supply	L	257
Fuel Rail Pressure	kPa	1215

Starter System		
Start Motor Voltage	V	24
No. of Batteries	2	

Air intake system		
Max allowable tem.	$^{\circ}\mathbb{C}$	17
Clean filter	kPa	3.74
Dirty filter	kPa	6.22

Cooling System		
Coolant capacity-engine	L	20.8
Thermostat (Modulating) Range	$^{\circ}\mathbb{C}$	82-94
Maximum Coolant Temperature	$^{\circ}\mathbb{C}$	96
Maximum Top Tank Temperature	$^{\circ}\mathbb{C}$	100

Lubrication System		
Total system capacity	L	38.6
Min idle Speed	kPa	103
Governed Speed	kPa	241-345

Exhaust system		
Max. exhaust temperature	$^{\circ}$	/
Standard Exhaust Pipe Diameter	mm	127
Max. allowed back pressure	kPa	10

### Alternator Specifications

Alternator Date	- IGNT	
Alternator Model		IA274K
Phase		3
Voltage (V)		400
Prime Power (KW)		200
Pole		4
Excitation System	lf-excited,	Brushless
No. of Bearing		1
Power Factor		0.8
Wiring Connection	3 Phases,	4 Wires
Insulation Grade		H/H
Protection Grade		IP23
Voltage Regulation (%)		$\pm 0.5$

Alternator Date-	- Stamford	
Alternator Model		S4L1D-C41/S4L1S-C4
Phase		3
Voltage	V	400
Prime Power	KW	200
Pole		4
Excitation System		elf-excited, Brushles
No. of Bearing		3
Power Factor		0.8
Wiring Connection		3 Phases, 4 Wires
Insulation Grade		$\mathrm{H}/\mathrm{H}$
Protection Grade		IP23
Voltage Regulation	%	$\pm 0.5$

## **IG275C**

# INDUSTRIAL RANGE POWER BY CUMMINS



### Controller Specifications

<u>-</u>	
Control Panel Date Deepsea DSE6120	
<ul> <li>Built in PLC logic programming</li> </ul>	lacktriangle Generator/load current monitoring and protection
<ul> <li>Generator voltage detection</li> </ul>	• Fuel pump control function
<ul><li>Mains voltage detection</li></ul>	• Can connect to all expansion modules
● Generator/load power detection (kW, kVA, kVAr, pf)	O Capable of graded loading
• Generator overload protection (kW)	<ul><li>Engine speed protection</li></ul>
• Equipped with manual closing and opening functions	○ Engine preheating
• Start gen-set when the battery voltage is low	<ul><li>Engine starts rapidly&amp;stops rapidly</li></ul>
<ul> <li>LCD and LED alarm indication</li> </ul>	Oustom remote start signal

### Generator Specifications

Standard Configuration	Optional Configuration
● 50°C radiator for belt driven fan	Battery charger
• 12/24V charging alternator	● Engine pre-heater
• One set of air/fuel/oil fiters	<ul><li>Alternator pre-heater</li></ul>
• Chassis with integrated fuel tank	● PMG/ AREP/ MAUX
<ul><li>Emergency stop button</li></ul>	● Water-oil seperator
• Anti-vibration shock absorbers	● Inside automatic transfer switch/ ATS box
● Main circuit breaker/ MCCB	• Grounding cooper rod
• Auto control system	Remote control system
• User manual	<ul><li>Switch box</li></ul>

#### Warranty of Generator Set

Cummins Engine

One year or 1000 running hours whichever comes first

#### Generator

One year or 1000 running hours whichever comes first

Email: ignt@igntpower.com Web: www.igntpower.com