

POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

STANDARD USAGE CONDITIONS:

1. Altitude: below 1000 meters; 2. Environmental temperature: 25 $^{\circ}\mathrm{C}$

3. Relative humidity: 30%

ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual.

The noise value we provide is based on

QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:

ISO 1400:2015 Environmental System;

ISO 45001:2018 Safty System; ISO 9001:2015 Quality System

SERVICE		PRP	ESP
Power	KVA	80	88
Power	KW	64	70
standard voltage	V	400,	/230
available voltage	V	380/220	415/240
Rated Current	A	115	
frequency/speed	hz/rpm	50/	1500

Weight and Dimension

Dimension		0pen	Silent
Length (L)	mm	1850	2540
Width (W)	mm	800	1000
Height (H)	mm	1260	1500
Net Weight	KG	1005	1375
Fuel Tank	L		112

IG88C

INDUSTRIAL RANGE POWER BY CUMMINS



Engine Specifications

General Engine Dat		
Engine Model	QSB3. 9-G3	
Aspiration	Turbo charged	air to air cooled
Fuel System	Common Rail	
No. of Cylinders		4
Displacement	L	3.9
Bore* Stroke	mm	102*120
Compression Ratio		17.3
Rated Net Power	KW	64
Governor Type		E
Rated speed	r/min	1500

Air intake syst	em	
Maximum intake air	restriction	
with heavy duty ai	r cleaner:	
Air flow	m3/min	83

Lubrication System		
Engine Oil Capcity	L	10.9
Oil Consumption	g/kWh	0.5
Oil Pressure	kPa	69

Alternator Specifications

Alternator Date	IGNI	
Alternator Model	IA224G	
Phase		3
Voltage	V	400
Prime Power	KVA	80
Pole		4
Excitation System	Self-excited	d, Brushless
No. of Bearing		1
Power Factor		0.8
Wiring Connection	3 Phase	es, 4 Wires
Insulation Grade		Н/Н
Protection Grade		IP23
Voltage Regulation	%	± 0.5

Fuel System				
Fuel Consumption @100% ESP	L/h	/		
Fuel Consumption @100% PRP	L/h	20		
Fuel Consumption @75% PRP	L/h	17		
Fuel Consumption @50% PRP	L/h	12		
Fuel Tank Capacity (Open)	L	120		
Fuel Tank Capacity (Silent)	L	/		

Starter System			
Start Motor Voltage	V	24	
No. of Batteries	4	2	

Cooling System				
Engine Coolant Capacity	L	7		
Thermostat Operating Range	$^{\circ}\!\mathbb{C}$	83-95		
Max. Water Temp.	$^{\circ}\!\mathbb{C}$	104		
Min. Pressure Cap	kPa	/		

Exhaust System		
Max. Exhaust Temp.	$^{\circ}\!\mathbb{C}$	415
Exhaust Gas Flow	m3/min	168
Max. Back Pressure	kPa	10

Alternator Date-	- Stamford	
Alternator Model	UCI	224G
Phase		3
Voltage	V	400
Prime Power	KVA	80
Pole		3
Excitation System	Self-excited,	Brushless
No. of Bearing		3
Power Factor		0.8
Wiring Connection	3 Phase	s, 4 Wires
Insulation Grade		H/H
Protection Grade		IP23
Voltage Regulation	%	± 0.5

IG88C

INDUSTRIAL RANGE POWER BY CUMMINS



Controller Specifications

Control	Pane1	Date	Deepsea	DSE6120
COLLET	1 and 1	Date	Deepsea	

- Built in PLC logic programming
- Mains voltage detection
- Generator overload protection (kW)
- Equipped with manual closing and opening functio Engine preheating
- Start gen-set when the battery voltage is low
- LCD and LED alarm indication

- Generator/load current monitoring and protection
- Can connect to all expansion modules
- Engine speed protection

- Engine starts rapidly&stops rapidly

Generator Specifications

Standard Configuration

- 50°C radiator for belt driven fan
- One set of air/fuel/oil fiters
- Emergency stop button
- Main circuit breaker/ MCCB
- Auto control system
- User manual

Optional Configuration

- Battery charger
- Alternator pre-heater
- Water-oil seperator
- Grounding cooper rod
- Switch box

Warranty of Generator Set

Generator

One year or 1000 running hours whichever comes first

