

POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

STANDARD USAGE CONDITIONS:

1. Altitude: below 1000 meters;

2. Environmental temperature: 25 ℃

3. Relative humidity: 30%

ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual.

The noise value we provide is based on

QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:

ISO 1400:2015 Environmental System;

ISO 45001:2018 Safty System;

ISO 9001:2015 Quality System

SERVICE		PRP	ESP
Power	KVA	150	165
Power	KW	120	132
standard voltage	V	400/230	
available voltage	V	380/220	415/240
Rated Current	A	2	17
frequency/speed	hz/rpm	50/	1500

Weight and Dimension

Dimension		0pen	Silent
Length (L)	mm	2400	3290
Width (W)	mm	950	1130
Height (H)	mm	1510	1850
Net Weight	KG	1375	1975
Fuel Tank	L		340

IG165C

INDUSTRIAL RANGE POWER BY CUMMINS



Engine Specifications

General Engine	Date Cummins		
Engine Model	6BTAA5. 9-G12		
Aspiration	Turbocharged and Charge Air Cooled		
Fuel Injection	Direct		
No. of Cylinders	6		
Displacement	L 5.9		
Bore* Stroke	mm 102*120		
Compression Ratio	17.3		
Rated Net Power	KW 120		
Governor Type	Е		
Cooling Way	Water-cooled		

Air intake system			
Maximum intake air re	estriction		
Intake air flow	L/s	150	
Cooling air flow	L/s	TBD	

Lubrication System		
Engine Oil Capcity	L	16. 4
Oil Consumption	%	0. 5-1
Oil Pressure	kPa	/

Alternator Specifications

Alternator Date	IGNT	
Alternator Model		IA274F
Phase		3
Voltage	V	400
Prime Power	KVA	150
Pole		4
Excitation System	Self-excited	d, Brushless
No. of Bearing		1
Power Factor		0.8
Wiring Connection	3 Phase	es, 4 Wires
Insulation Grade		Н/Н
Protection Grade		IP23
Voltage Regulation	%	±0.5
-		

Fuel System		
Fuel Consumption @100% ESP	L/h	38
Fuel Consumption @100% PRP	L/h	34
Fuel Consumption @75% PRP	L/h	26
Fuel Consumption @50% PRP	L/h	17
Fuel Tank Capacity (Open)	L	270
Fuel Tank Capacity (Silent)	L	330

Starter System		
Start Motor Voltage	V	24
No. of Batteries	2	

Cooling System		
Total Coolant Capacity	L	26.4
Engine oil capacity	L	16.4
Air Filte	Type	Dry
Min. Pressure Cap	kPa	/

Exhaust System		
Max. Exhaust Temp.	$^{\circ}\!\mathbb{C}$	507
Exhaust Gas Flow	L/s	357
Max. Back Pressure	kPa	10

Alternator Date-	Stamford	
Alternator Model		UCI274F
Phase		3
Voltage	V	400
Prime Power	KVA	150
Pole		3
Excitation System	Self-excited,	Brushless
No. of Bearing		3
Power Factor		0.8
Wiring Connection	3 Phase	s, 4 Wires
Insulation Grade		Н/Н
Protection Grade		IP23
Voltage Regulation	%	± 0.5

IG165C

INDUSTRIAL RANGE POWER BY CUMMINS



Controller Specifications

Control	Pana1	Data	Deengas	DSE6120
COLLTIOL	ranei	Date	Deepsea	DOLUIZU

- Built in PLC logic programming
- Generator voltage detection
- Mains voltage detection
- Generator/load power detection (kW. kVA. kVAr.
- Generator overload protection (kW)
- Equipped with manual closing and opening functio● Engine preheating
- Start gen-set when the battery voltage is low
- LCD and LED alarm indication

- lacktriangle Generator/load current monitoring and protection
- Fuel pump control function
- Can connect to all expansion modules
- p Capable of graded loading
- Engine speed protection
- Eligine speed protection
- Engine starts rapidly&stops rapidly
- Custom remote start signal

Generator Specifications

Standard Configuration

- 50°C radiator for belt driven fan
- 12/24V charging alternator
- One set of air/fuel/oil fiters
- Chassis with integrated fuel tank
- Emergency stop button
- Anti-vibration shock absorbers
- Main circuit breaker/ MCCB
- Auto control system
- User manual

Optional Configuration

- Battery charger
- Engine pre-heater
- Alternator pre-heater
- PMG/ AREP/ MALIX
- Water-oil seperator
- Inside automatic transfer switch/ ATS box
- Grounding cooper rod
- Remote control system
- Switch box

Warranty of Generator Set

Cummine Engine

One year or 1000 running hours whichever comes first

Generator

One year or 1000 running hours whichever comes first



