

POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

STANDARD USAGE CONDITIONS:

1. Altitude: below 1000 meters;

2. Environmental temperature: 25 ℃

3. Relative humidity: 30%

ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual.

The noise value we provide is based on

QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:

ISO 1400:2015 Environmental System;

ISO 45001:2018 Safty System;

ISO 9001:2015 Quality System

SERVICE		PRP	ESP
Power	KVA	250	275
Power	KW	200	220
standard voltage	V	400/	/230
available voltage	V	380/220	415/240
Rated Current	A	36	61
frequency/speed	hz/rpm	50/1	1500

Weight and Dimension

Dimension		0pen	Silent
Length (L)	mm	2650	3590
Width (W)	mm	1000	1180
Height (H)	mm	1800	2150
Net Weight	KG	1940	2660
Fuel Tank	L		430

IG275C

INDUSTRIAL RANGE POWER BY CUMMINS



Engine Specifications

General Engine	
Engine Model	6LTAA8. 9-G2
Aspiration	/
Piston Speed	m/s 7.3
No. of Cylinders	6
Displacement	L 8.9
Bore* Stroke	mm 114*145
Compression Ratio	16.6
Rated Net Power	KW 200
Governor Type	Е
Engine Weight	kg 650

Maximum intake air restriction	
with heavy duty air cleaner:	
Air Intake Flow L/s	248

Lubrication System		
Engine Oil Capcity	L	27.6
Max. oil temperature	$^{\circ}\!\mathbb{C}$	121
Low idle	kPa	103

Alternator Specifications

Alternator Date	1GNT	
Alternator Model	IAS	274K
Phase		3
Voltage	V	400
Prime Power	KVA	250
Pole		4
Excitation System	Self-excite	ed, Brushless
No. of Bearing		1
Power Factor		0.8
Wiring Connection	3 Phas	es, 4 Wires
Insulation Grade		Н/Н
Protection Grade		IP23
Voltage Regulation	%	± 0.5

Fuel System		
Fuel Consumption @110% ESP	L/h	58
Fuel Consumption @100% PRP	L/h	53
Fuel Consumption @75% PRP	L/h	39
Fuel Consumption @50% PRP	L/h	27
Maximum Restrict	kPa	20.3
Maximum Fuel Inlet Temp	$^{\circ}\mathbb{C}$	70

Starter System		
Start Motor Voltage	V	24
No. of Batteries		2

Cooling System		
Engine Coolant Capacity	L	11.1
Thermostat Operating Range	$^{\circ}\!\mathbb{C}$	82-95
Minimum Pressure	kPa	103
Max. coolant cycling	kPa	28

Exhaust System		
Max. Exhaust Temp.	$^{\circ}\mathbb{C}$	/
Exhaust Gas Flow	L/s	584
Max. Back Pressure	kPa	10.1

Alternator Date	Stamford	
Alternator Model	S4L1	D-C41
Phase		3
Voltage	V	400
Prime Power	KVA	250
Pole		3
Excitation System	Self-excited,	Brushless
No. of Bearing		3
Power Factor		0.8
Wiring Connection	3 Phase	s, 4 Wires
Insulation Grade		Н/Н
Protection Grade		IP23
Voltage Regulation	%	± 0.5

IG275C

INDUSTRIAL RANGE POWER BY CUMMINS



Controller Specifications

Cantral	Doma1	Data	Dasmass	DCEC 190
Control	ranei	vate	Deepsea	DSEOIZU

- Built in PLC logic programming
- Mains voltage detection

- Generator overload protection (kW)
- Equipped with manual closing and opening functio Engine preheating
- Start gen-set when the battery voltage is low

- Generator/load current monitoring and protection
- Fuel pump control function
- Can connect to all expansion modules
- Engine speed protection
- Engine starts rapidly&stops rapidly

Generator Specifications

Standard Configuration

- 50°C radiator for belt driven fan
- One set of air/fuel/oil fiters
- Emergency stop button
- Main circuit breaker/ MCCB
- User manual

Optional Configuration

- Battery charger
- Alternator pre-heater
- Water-oil seperator
- Inside automatic transfer switch/ ATS box
- Grounding cooper rod
- Switch box

Warranty of Generator Set

Generator

One year or 1000 running hours whichever comes first



