

POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

STANDARD USAGE CONDITIONS:

1. Altitude: below 1000 meters;

2. Environmental temperature: 25 ℃

3. Relative humidity: 30%

ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual.

The noise value we provide is based on

QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:

ISO 1400:2015 Environmental System;

ISO 45001:2018 Safty System:

| SERVICE | | PRP | ESP |
|-------------------|--------|---------|---------|
| Power | KVA | 450 | 495 |
| Power | KW | 360 | 396 |
| standard voltage | V | 400/230 | |
| available voltage | V | 380/220 | 415/240 |
| Rated Current | A | 650 | |
| frequency/speed | hz/rpm | 50/1 | 500 |

Weight and Dimension

| Dimension | | 0pen | Silent |
|------------|----|------|--------|
| Length (L) | mm | 3500 | 4590 |
| Width (W) | mm | 1300 | 1600 |
| Height (H) | mm | 2050 | 2500 |
| Net Weight | KG | 3370 | 4820 |
| Fuel Tank | L | | 690 |

IG495C

INDUSTRIAL RANGE POWER BY CUMMINS



Engine Specifications

| General Engine | | | |
|-------------------|----|-----|------------|
| Engine Model | | | QSZ13-G2 |
| Aspiration | | | Turbo, Air |
| Fuel system | | | HPCR |
| No. of Cylinders | | | 6 |
| Displacement | | L | 13 |
| Bore* Stroke | 1 | mm | 130*163 |
| Compression Ratio | | | 17. 1 |
| Rated Net Power |] | KW | 360 |
| Governor Type | | | ECU |
| Rated speed | r/ | min | 1500 |

| Air intake syste | em | |
|---------------------|-------------|-----|
| Maximum intake air | restriction | |
| with heavy duty air | cleaner: | |
| Rated Net Power | kw | 360 |
| | | |

| Lubrication System | | | |
|--------------------|-------|------------|--|
| Engine Oil Capcity | L | 45. 4 | |
| Oil Consumption | g/kWh | ≤ 4 | |
| Oil Pressure | kPa | 82. 7 | |

Alternator Specifications

| Alternator Date | IGNT | |
|--------------------|---------------|-----------|
| Alternator Model | | IA544B |
| Phase | | 3 |
| Voltage | V | 400 |
| Prime Power | KVA | 450 |
| Pole | | 4 |
| Excitation System | Self-excited, | Brushless |
| No. of Bearing | | 1 |
| Power Factor | | 0.8 |
| Wiring Connection | 3 Phases | , 4 Wires |
| Insulation Grade | | H/H |
| Protection Grade | | IP23 |
| Voltage Regulation | % | ± 0.5 |
| • | | |

| Fuel System | | |
|-----------------------------|-----|------|
| Fuel Consumption @100% ESP | L/h | / |
| Fuel Consumption @100% PRP | L/h | 88.8 |
| Fuel Consumption @75% PRP | L/h | 65.5 |
| Fuel Consumption @50% PRP | L/h | 44.2 |
| Fuel Tank Capacity (Open) | L | 780 |
| Fuel Tank Capacity (Silent) | L | / |

| Starter System | | |
|---------------------|---|----|
| Start Motor Voltage | V | 24 |
| No. of Batteries | 6 | 2 |

| Cooling System | | |
|----------------------------|------------------------|------|
| Engine Coolant Capacity | L | 23.1 |
| Thermostat Operating Range | $^{\circ}\!\mathbb{C}$ | 82 |
| Max. Water Temp. | $^{\circ}$ C | 102 |
| Min. Pressure Cap | kPa | / |

| Exhaust System | | |
|--------------------|----------------------|------|
| Max. Exhaust Temp. | $^{\circ}\mathbb{C}$ | 509 |
| Exhaust Gas Flow | L/s | 34.7 |
| Max. Back Pressure | kPa | 13 |

| Alternator Date | Stamford | |
|--------------------|---------------|------------|
| Alternator Model | S4L1 | D-G41 |
| Phase | | 3 |
| Voltage | V | 400 |
| Prime Power | KVA | |
| Pole | | 3 |
| Excitation System | Self-excited, | Brushless |
| No. of Bearing | | 3 |
| Power Factor | | 0.8 |
| Wiring Connection | 3 Phase | s, 4 Wires |
| Insulation Grade | | H/H |
| Protection Grade | | IP23 |
| Voltage Regulation | % | ± 0.5 |

IG495C

INDUSTRIAL RANGE POWER BY CUMMINS



Controller Specifications

| 0 1 1 | D 1 | D. I | D | DCEC100 |
|---------|-------|------|---------|-----------|
| Control | Panel | пате | Deensea | - DSEGTZU |

- Built in PLC logic programming
- Mains voltage detection
- Generator overload protection (kW)
- Dequipped with manual closing and opening functio Engine preheating Start gen-set when the battery voltage is low

- Generator/load current monitoring and protection
- Fuel pump control function
- Can connect to all expansion modules
- Engine speed protection
- Engine starts rapidly&stops rapidly

Generator Specifications

Standard Configuration

- 50°C radiator for belt driven fan
- One set of air/fuel/oil fiters
- Emergency stop button
- Main circuit breaker/ MCCB
- User manual

Optional Configuration

- Battery charger
- Alternator pre-heater
- Water-oil seperator
- Inside automatic transfer switch/ ATS box
- Grounding cooper rod
- Switch box

Warranty of Generator Set

Generator

One year or 1000 running hours whichever comes first



649.44