

POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

STANDARD USAGE CONDITIONS:

1. Altitude: below 1000 meters;

2. Environmental temperature: 25 ℃

3. Relative humidity: 30%

ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual.

The noise value we provide is based on

QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:

ISO 1400:2015 Environmental System;

ISO 45001:2018 Safty System;

ISO 9001:2015 Quality System

SERVICE		PRP	ESP
Power	KVA	225	250
Power	KW	180	198
standard voltage	V	400,	/230
available voltage	V	380/220	415/240
Rated Current	A	32	25
frequency/speed	hz/rpm	50/1	1500

Weight and Dimension

Dimension		0pen	Silent
Length (L)	mm	2650	3590
Width (W)	mm	1100	1280
Height (H)	mm	1800	2150
Net Weight	KG	1795	2475
Fuel Tank	L		400

IG250C

INDUSTRIAL RANGE POWER BY CUMMINS



Engine Specifications

General Engine	Date Cum	mins	
Engine Model	QSL8. 9-G3		
Aspiration	Turbocharged, air-to-air cold		
Cycle		4	
No. of Cylinders		6	
Displacement	L	8.9	
Bore* Stroke	mm	114*145.5	
Compression Ratio		17. 7	
Rated Net Power	KW	180	
Governor Type		ECU	
Oil Capcity	L	28. 1	

2kpa

Lubrication System		
Total system Capcity	L	28. 1
Idle speed	kPa	69
Max Oil temperature	$^{\circ}\!\mathbb{C}$	121

Alternator Specifications

Alternator Date	IGNT	
Alternator Model		IA274J
Phase		3
Voltage	V	400
Prime Power	KVA	225
Pole		4
Excitation System	Self-excited,	Brushless
No. of Bearing		1
Power Factor		0.8
Wiring Connection	3 Phases	s, 4 Wires
Insulation Grade		H/H
Protection Grade		IP23
Voltage Regulation	%	± 0.5

Fuel System			
Fuel Consumption @100%	ESP	L/h	/
Fuel Consumption @100%	PRP	L/h	/
Type Injection	E16	ectronically	controlled
Cranking Motor Vol			DC24V
Oil Pan capacity(low)	L	23. 5
Oil Pan capacity(hig	h)	L	17.8

Starter System		
Start Motor Voltage	V	24
No. of Batteries	6	2

Cooling System		
Engine Coolant Capacity	L	11.1
Thermostat Operating Range	$^{\circ}\mathbb{C}$	82-95℃
Total system	L	57.1
Min. Pressure Cap	kPa	103

Exhaust System		
Max. Exhaust Temp.	$^{\circ}\mathbb{C}$	/
Standard exhaust pipe diama	mm	100
Max. Back Pressure	kPa	10

Alternator Date-	- Stamford	
Alternator Model		UCDI274J
Phase		3
Voltage	V	400
Prime Power	KVA	225
Pole		3
Excitation System	Self-excited,	Brushless
No. of Bearing		3
Power Factor		0.8
Wiring Connection	3 Phase	s, 4 Wires
Insulation Grade		Н/Н
Protection Grade		IP23
Voltage Regulation	%	± 0.5

IG250C

INDUSTRIAL RANGE POWER BY CUMMINS



Controller Specifications

Control	Dono1	Do+	Doorgoo	DSE6120
	гапет	Date	Deepsea	DOLUIZU

- Built in PLC logic programming
- Generator voltage detection
- Mains voltage detection
- Generator/load power detection (kW. kVA. kVAr.
- deficiator/ load power detection (kw, kvh, kv
- Generator overload protection (kW)
- Start gen-set when the battery voltage is low
- O ICD and IED alarm indication
- Equipped with manual closing and opening functio Engine preheating
 - Engine starts rapidly&stops rapidly

• Generator/load current monitoring and protection

• Can connect to all expansion modules

• Custom remote start signal

• Engine speed protection

Generator Specifications

Standard Configuration

- 50°C radiator for belt driven fan
- 12/24V charging alternator
- One set of air/fuel/oil fiters
- Chassis with integrated fuel tank
- Emergency stop button
- Anti-vibration shock absorbers
- Main circuit breaker/ MCCB
- Auto control system
- User manual

Optional Configuration

- Battery charger
- Engine pre-heater
- Alternator pre-heater
- PMG/ AREP/ MALIX
- Water-oil seperator
- Inside automatic transfer switch/ ATS box
- Grounding cooper rod
- Remote control system
- Switch box

Warranty of Generator Set

Cummine Engine

One year or 1000 running hours whichever comes first

Generator

One year or 1000 running hours whichever comes first

