

POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

STANDARD USAGE CONDITIONS:

1. Altitude: below 1000 meters;

2. Environmental temperature: 25 ℃

3. Relative humidity: 30%

ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual. The noise value we provide is based on laboratory testing and is for reference.

QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:

ISO 1400:2015 Environmental System;

ISO 45001:2018 Safty System; ISO 9001:2015 Quality System

SERVICE		PRP	ESP
Power	KVA	750	825
Power	KW	600	660
Standard Voltage	V	400/	/230
Available Voltage	V	380/220	415/240
Rated Current	A	10	83
Frequency/Speed	HZ/RPM	50/1	1500

Weight and Dimension

	Dimension	1	0pen	Silent
Length	(L)	mm	4000	5680
Width	(W)	mm	1650	2100
Height	(H)	mm	2100	2500
Net Weigh	t	KG		
Fuel Tank		L		

IG825M

INDUSTRIAL RANGE POWER BY SME



Engine Specifications

General Engine Date	SME
Engine Model	S6R2-PTAA-C
Governer	Е
Number of Turbocharger	4
No. of Cylinders	6
Displacement (L)	29.96
Bore* Stroke (mm)	170*220
Compression Ratio	14. 1
Rated Net Power (KW)	600
Approximate engine weight	2850kg

Fuel System		
Fuel Consumption @100% ESP	L/h	175
Fuel Consumption @100% PRP	L/h	157
Fuel Consumption @75% PRP	L/h	119
Fuel Consumption @50% PRP	L/h	82
Fuel Tank Capacity (Open)	L	/
Fuel Tank Capacity (Silent)	L	/

Starter System		
Start Motor Voltage	V	24
No. of Batteries	2	2

Air intake system

Air cleaner	Donalds	on EG	B 15x 2 pcs
Turbocharger	Mitsubishi	type	TF15L-60QV (49)
Air co	oler	Plate	ed element type

Cooling System	
Water pump	Belt drive centrifugal type
Capacity of water	pump 1500min-1, 820 L/min
Thermostat	Wax pellet type x 2pcs

Lubrication System Engine Oil Capcity L/min 270 Oil pressure at main gallery 0.5-0.65Mpa oil cooler Water cooled corrugated fin type

Control system	
Connector	Loose supply
Potentiometer	Not supply
Magnetic pick up	With connector

Alternator Specifications

Alternator Date	- IGNT	
Alternator Model		IA634B
Phase		3
Voltage (V)		400
Prime Power (KW)		600
Pole		4
Excitation System	lf-excited,	Brushless
No. of Bearing		1
Power Factor		0.8
Wiring Connection	3 Phases,	4 Wires
Insulation Grade		Н/Н
Protection Grade		IP23
Voltage Regulation (%)		± 0.5

Alternator Date	Stamford	
Alternator Model		S5L1D-H4
Phase		3
Voltage	V	400
Prime Power	KW	600
Pole		4
Excitation System		elf-excited, Brushles
No. of Bearing		3
Power Factor		0.8
Wiring Connection		3 Phases, 4 Wires
Insulation Grade		Н/Н
Protection Grade		IP23
Voltage Regulation	%	± 0.5

IG825M

INDUSTRIAL RANGE POWER BY SME



Controller Specifications

Control Panel Date Deepsea DSE6120	
 Built in PLC logic programming 	• Generator/load current monitoring and protection
• Generator voltage detection	• Fuel pump control function
 Mains voltage detection 	• Can connect to all expansion modules
● Generator/load power detection (kW, kVA, kVAr, pf)	● Capable of graded loading
Generator overload protection (kW)	Engine speed protection
• Equipped with manual closing and opening functions	Engine preheating
• Start gen-set when the battery voltage is low	• Engine starts rapidly&stops rapidly
● LCD and LED alarm indication	O Custom remote start signal

Generator Specifications

Standard Configuration	Optional Configuration
● 50°C radiator for belt driven fan	Battery charger
● 12/24V charging alternator	● Engine pre-heater
• One set of air/fuel/oil fiters	● Alternator pre-heater
• Chassis with integrated fuel tank	● PMG/ AREP/ MAUX
Emergency stop button	● Water-oil seperator
• Anti-vibration shock absorbers	● Inside automatic transfer switch/ ATS box
● Main circuit breaker/ MCCB	• Grounding cooper rod
• Auto control system	• Remote control system
• User manual	Switch box

Warranty of Generator Set

Cummins Engine

One year or 1000 running hours whichever comes first

Generator

One year or 1000 running hours whichever comes first

Email: ignt@igntpower.com Web: www.igntpower.com