

POWER DEFINITION

PRP: Prime Power is required for continuous operation under variable load and infinite operating hours per year.

ESP: Standby power refers to the ability of the generator to operate at varying loads in the event of power outage, with an annual operating time of up to 200h.

STANDARD USAGE CONDITIONS:

1. Altitude: below 1000 meters;

2. Environmental temperature: 25 ℃

3. Relative humidity: 30%

ABOUT NOISE:

The noise level of the generator largely depends on the installation conditions and usage environment, so it is not possible to specify the noise value in manual. The noise value we provide is based on laboratory testing and is for reference.

QUALIFICATION STANDARD

IGNT POWER generator set complies with ISO and CE standards, which also include the following certification standards:

ISO 1400:2015 Environmental System;

ISO 45001:2018 Safty System; ISO 9001:2015 Quality System

SERVICE		PRP	ESP
Power	KVA	94	103
Power	KW	75	83
Standard Voltage	V	400,	/230
Available Voltage	V	380/220	415/240
Rated Current	A	1:	35
Frequency/Speed	HZ/RPM	50/	1500

Weight and Dimension

	Dimension	ı	0pen	Silent
Length	(L)	mm	2050	2940
Width	(W)	mm	880	1080
Height	(H)	mm	1230	1690
Net Weigh	t	KG		
Fuel Tank		L	1000	232

IG103WP

INDUSTRIAL RANGE POWER BY WEICHAI



Engine Specifications

General Engine Date	WEICHAI
Engine Model	WP4.1D100E200
Governer	E
Aspiration Turbocharg	ged & Intercooling
No. of Cylinders	4
Displacement (L)	4.1
Bore* Stroke (mm)	105*118
Compression Ratio	17.5
Rated Net Power(KW) with fa	n 90
Fuel system	mechanical pump

Fuel System		
Fuel Consumption @100% ESP	L/h	/
Fuel Consumption @100% PRP	L/h	18. 7
Fuel Consumption @75% PRP	L/h	/
Fuel Consumption @50% PRP	L/h	/
Fuel Tank Capacity	L	360
Fuel Tank Capacity (Silent)	L	/

Starter System		
Start Motor Voltage	V	24
No. of Batteries	2	

Aspiration syst	em	
Clean filter	kPa	€3
Dirty filter	kPa	/
Air flow	m3/min	445

Cooling System		
Total coolant capacity	L	9.4
Thermostat operation range	$^{\circ}\mathbb{C}$	76-89
Max water temperature	$^{\circ}\mathbb{C}$	98

Lubrication System		
Oil capacity	L	13
Oil consumption	g/kwh	0.5
Oil pressure	kPa	300-500

Exhaust system		
Max. exhaust temperature	$^{\circ}\mathbb{C}$	560
Exhaust gas flow	L/s	463
Max. allowed back pressure	kPa	10

Alternator Specifications

Alternator Date	- IGNT	
Alternator Model		IA274C
Phase		3
Voltage (V)		400
Prime Power (KW)		75
Pole		4
Excitation System	lf-excited,	Brushless
No. of Bearing		1
Power Factor		0.8
Wiring Connection	3 Phases,	4 Wires
Insulation Grade		H/H
Protection Grade		IP23
Voltage Regulation (%)		± 0.5

Alternator Date-	- Stamfor	\cdot d
Alternator Model		UCI274C
Phase		3
Voltage	V	400
Prime Power	KW	75
Pole		4
Excitation System		elf-excited, Brushles
No. of Bearing		3
Power Factor		0.8
Wiring Connection		3 Phases, 4 Wires
Insulation Grade		Н/Н
Protection Grade		IP23
Voltage Regulation	%	± 0.5

IG103WP

INDUSTRIAL RANGE POWER BY WEICHAI



Controller Specifications

Control Panel Date Deepsea DSE6120	
Built in PLC logic programming	• Generator/load current monitoring and protection
• Generator voltage detection	• Fuel pump control function
Mains voltage detection	 Can connect to all expansion modules
● Generator/load power detection (kW, kVA, kVAr, pf)	 Capable of graded loading
• Generator overload protection (kW)	Engine speed protection
• Equipped with manual closing and opening functions	Engine preheating
• Start gen-set when the battery voltage is low	• Engine starts rapidly&stops rapidly
● LCD and LED alarm indication	O Custom remote start signal

Generator Specifications

Standard Configuration	Optional Configuration
● 50°C radiator for belt driven fan	Battery charger
• 12/24V charging alternator	● Engine pre-heater
• One set of air/fuel/oil fiters	Alternator pre-heater
• Chassis with integrated fuel tank	● PMG/ AREP/ MAUX
Emergency stop button	● Water-oil seperator
• Anti-vibration shock absorbers	● Inside automatic transfer switch/ ATS box
● Main circuit breaker/ MCCB	• Grounding cooper rod
• Auto control system	Remote control system
• User manual	Switch box

Warranty of Generator Set

Cummins Engine

One year or 1000 running hours whichever comes first

Generator

One year or 1000 running hours whichever comes first

Email: ignt@igntpower.com Web: www.igntpower.com